



REPORT

issued by notified body No. 0402

Handled by, department
Marina C Andersson
Fire Technology
+46 10 516 52 92, marina.andersson@sp.se

0402 – CPD – P502024A

Date	Reference	Page
2005-10-19	P502024A / rev 5	1 (5)
Rev.date		
2008-08-25		

Tarkett AB
372 81 RONNEBY

Reaction to fire classification report

1 Introduction

This classification report defines the classification assigned to resilient floor coverings in accordance with the procedure given in EN 13501-1:2007.

This classification report replace SP classification report P502024A / rev 4, dated March 10, 2008.

2 Details of classified product

2.1 General

The products are defined as a resilient floor coverings. Their classification is valid for the end use application as floor coverings for indoor use.

According to the owner of this classification report, this product complies with the European product specification EN 14041:2004.

2.2 Product description

The products are fully described below.

According to the client:

Homogeneous vinyl flooring, produced on different production lines at the plant in Ronneby with organic content consisting of polyvinylchloride, plasticizer, and stabilizer, non-organic fillers and surface of PUR.

SP Technical Research Institute of Sweden

<i>Postal address</i>	<i>Office location</i>	<i>Phone / Fax / E-mail</i>
SP Box 857 SE-501 15 Borås SWEDEN	Västeråsen Brinellgatan 4 SE-504 62 Borås SWEDEN	+46 10 516 50 00 +46 33 13 55 02 info@sp.se

Swedish Notified Bodies are appointed by SWEDAC, the Swedish Board for Accreditation and Conformity Assessment, under the terms of Swedish legislation. This report may not be reproduced other than in full, except with the prior written approval of SP.

Table 1. Products

Product name	Nominal content of non-organic fillers *) (%)	Nominal area weight (g/m ²)	Nominal thickness (mm)
iQ Megalit	15-20	2690	2.0
iQ Gemstone	10-15	2690	2.0
iQ Optima	20-25	2100 – 2800	1.5 – 2.0
Monolit	20-25	2940	2.0
Eminent Safe.T	20-25	2940	2.0
iQ Eminent	30-35	3000	2.0
iQ Granit	30-35	3000	2.0
Stone	30-35	2920	2.0
Stabilon	30-35	3000	2.0
Somplan 500	30-35	3060	2.0
Eurovinyl	30-35	3000	2.0
IKEA special	30-35	3090	2.0
Curry's special	30-35	3090	2.0
Scapino	30-35	3090	2.0
Primo Plus	40-45	3150	2.0
Primo Premium	40-45	3150	2.0
Micra Premium	40-45	3060	2.0
Micro Plus	40-45	3150	2.0
Eclipse	40-45	3150	2.0
Eclipse PUR	40-45	3150	2.0
Eclipse Premium	40-45	3150	2.0
Somplan Plus	50-55	3400	2.0
Harlequin marine	50-55	3400	2.0
iQ Toro SC**)	20-25	3000	2.0
Toro EL **)	30-35	3000	2.0

*) The exact amount of the non-organic content of the product is held on file by SP

***) Permanently static conductive pressed homogeneous vinyl flooring

3 Test reports & test results in support of classification

3.1 Test reports

This classification is based on the test report listed below:

Name of laboratory	Name of sponsor	Test report ref no	Test method
SP	Tarkett AB	P502024	EN ISO 9239-1 EN ISO 11925-2
SP	Tarkett AB	P603076	EN ISO 9239-1 EN ISO 11925-2
SP	Tarkett AB	P800072D	EN ISO 9239-1 EN ISO 11925-2

3.2 Test results

The test results listed below show the worst case as found in the test programme performed and reported according to the table above. The GNB-CPD position paper from SH02 – EN 14041:2004 Fire testing and classification of resilient, textile and laminate floorings – NB-CPD/SH02/06/033 – from the group of notified bodies, has been applied in the process of selecting suitable products for testing.

Test method	Parameter	Number of tests	Results	
			Continuous parameter mean (m)	Compliance with parameters
EN ISO 11925-2		6		
15 s exposure	$F_s \leq 150$ mm		(-)	Compliant
EN ISO 9239-1		3		
	<i>Critical flux</i> (kW/m ²)		8.5	Compliant
	<i>Smoke</i> (%.min)		367	Compliant

(-) : not applicable

4 Classification and field of application

4.1 Reference and direct field of application

This classification has been carried out in accordance with clause 12 and 15 of EN 13501-1:2007.

4.2 Classification

The products as listed in table 1 in this report in relation to its reaction to fire behaviour is classified:

The additional classification in relation to smoke production is:
 B_{fl}
 s1

The format of the reaction to fire classification for floorings is:

Fire Behaviour		Smoke Production	
B_{fl}	-	s	1

Reaction to fire classification: B_{fl-s1}

4.3 Field of application:

This classification is valid for the following product parameters:

Nominal content of non-organic fillers: (see table 1 in this report).

Nominal area weight: (see table 1 in this report).

This classification is valid for the following end use applications:

Substrates

- Wood based substrates or substrates of Euroclass A1_{fl} or A2_{fl}, having density $\geq 510 \text{ kg/m}^3$.

5 Limitations


This classification document does not represent type approval or certification of the product.

“The classification assigned to the product in this report is appropriate to a declaration of conformity by the manufacturer within the context of system 3 attestation of conformity and CE marking under the Construction Products Directive.

The manufacturer has made a declaration, which is held on file. This confirms that the product’s design requires no specific processes, procedures or stages (e.g. no addition of flame-retardants, limitation of organic content, or addition of fillers) that are aimed at enhancing the fire performance in order to obtain the classification achieved. As a consequence the manufacturer has concluded that system 3 attestation is appropriate.

The test laboratory has, therefore, played no part in sampling the product for the test, although it holds appropriate references to the manufacturer’s factory production control that is claimed to be relevant to the samples tested and that will provide for their traceability.”

SP Technical Research Institute of Sweden
Fire Technology – Fire Dynamics



Per Thureson
Technical Manager



Marina C Andersson
Technical Officer